



## **VILLAGE OF MONTROSE**

### **2014 ANNUAL REPORT OF WATER MONITORING**

**August 2015**

PO BOX 510  
MONTROSE, BC V0G 1P0  
Phone :(250) 367-7234 - Fax :(250) 367-7288  
E-mail: [admin@montrose.ca](mailto:admin@montrose.ca)  
Website: [www.montrose.ca](http://www.montrose.ca)

## Table of Contents

---

	Page
<b>1.0 Introduction</b>	3
<b>2.0 Water System Overview</b>	4
2.1 Service Area	4
2.2 Source	4
2.3 Treatment	5
2.4 Storage	6
2.5 Distribution System	6
2.6 Controls and Communications	6
<b>3.0 Water System Maintenance</b>	7
3.1 Wells Maintenance	7
3.2 Reservoirs Maintenance	7
3.3 Distribution System Maintenance	7
3.3.1 Valve Inspection	7
3.3.2 Watermain Flushing and Hydrant Maintenance	8
3.3.3 Watermain Breaks	8
<b>4.0 Water System Operator Training Program</b>	9
<b>5.0 Monitoring and Testing Program</b>	10
5.1 Parameters	10
5.2 Results	11
<b>6.0 Annual Consumption Records</b>	13
<b>7.0 Water Conservation</b>	14
<b>8.0 Water Issues in 2014</b>	15
<b>9.0 2014 Capital Works and Projected 2015 Capital Works</b>	16
<b>10.0 Emergency Response and Contingency Plan</b>	18
<b>11.0 Conclusion</b>	19

## APPENDIX

- Appendix 1: Montrose Water Service Area
- Appendix 2: 2014 Drinking Water Bacteriology Summary
- Appendix 3: 2014 Chlorine Residual Monitoring Summary
- Appendix 4: 2014 Water Consumption Records
- Appendix 5: Emergency Response Plan (Policies # 5600 and #7130)

## **1.0 Introduction**

---

This report has been produced to meet the requirement for water suppliers to produce an annual report on water quality as per Section 15 of the *Drinking Water Protection Act* and Section 11(b) of the Drinking Water Protection Regulation.

The annual report covers the period from January 1, 2014 to December 31, 2014 and uses data that is regularly obtained by the Village of Montrose to highlight water quality issues and to discuss the monitoring results of the Village's water system.

This report aims to convey information to residents regarding the overall operation of the municipal water system and describe the Village's approach to the operation and maintenance of the water system.

For more detailed information on drinking water health effects, the Village of Montrose recommends the following web sites:

**Interior Health Authority**

<http://www.interiorhealth.ca/YourEnvironment/DrinkingWater/Pages/default.aspx>

**Health Canada:**

<http://www.hc-sc.gc.ca/ewh-semt/water-eau/drink-potab/index-eng.php>

**World Health Organization:**

[http://www.who.int/water\\_sanitation\\_health/dwq/en/](http://www.who.int/water_sanitation_health/dwq/en/)

## **2.0 Water System Overview**

---

The Village of Montrose was incorporated in 1956 and is home to approximately 1000 residents. It serves predominantly as a bedroom community to the City of Trail and is located within the Beaver Valley, east of the City of Trail and west of the Village of Fruitvale.

The Village of Montrose is currently classified as a Level II water distribution system. It obtains its domestic water supply from two wells that lay outside the Village boundaries, near the confluence of Beaver Creek and the Columbia River. This source is the most reliable and economical water supply for the Village. Water drawn from the two wells is now chlorinated and pumped up to two reservoirs located within the Village, which gravity feed the distribution system. In times of peak demand, some residents receive water directly from the wells.

In February of 2011, upon IHA recommendation, the Village was placed on a Boil Water Notice. The notice was issued due to routine testing showing a persistent low total coliform presence. The Village was still operating under this notice until June 27, 2013 upon completion of a major Gas Tax funded project which provided the Village with a new well, chlorine treatment facility and back-up power.

### **2.1 Service Area**

The current water system supplies domestic water to both residents and businesses located within Village boundaries (Appendix 1). In addition, it acts as the only source of fire protection to the Village. It also acts as a backup system to the Beaver Falls Waterworks District, which supplies water to some 500 residents of the Beaver Valley (the area that lies between the Village of Montrose and Village of Fruitvale).

### **2.2 Source**

As stated above, the Village currently has two production wells located at the confluence of the Beaver Creek and Columbia River. Both wells draw from an unconfined groundwater source.

Well #1 was constructed in 1961 and provided for an estimated safe yield of 47.3 L/s. In 1998, Kala Groundwater Consulting Ltd. was contacted to re-evaluate the well. Upon completion of their investigation, Well #1 was found to suffer from excessive drawdown, and as a result, the well's safe yield was reassessed to approximately 28.4 L/s. A recent (2009) assessment of the well references Kala's safe rate of 28.4 L/s and notes that the well efficiency is declining over time.

Well #2 was constructed in 1981 and provided for an estimated safe yield of 20.8 L/s. Again, in 1998, Kala Groundwater determined that Well #2 could safely be continuously pumped at 21 L/s. At the typical safe design rate of operating for eighteen hours per day, Well #2 can provide the Village with approximately 1,361 m<sup>3</sup>/day. Well #2 has had issues with ground subsidence since the initial development which has caused settlement of the pumphouse building. Due to this settlement, this well has been capped and

abandoned upon completion of Well #3 which was commissioned as part of a major project to disinfect the Villages' water supply. This well could be used in an emergency situation and will remain capped for this purpose.


Specifics	Well #1		Well #2		Well #3
	<i>Original</i>	<i>Current</i>	<i>Original</i>	<i>Current</i>	<i>Original</i>
1. Year Drilled	1961		1981		2013
2. Total Depth (m)	38.1		36		34.7
3. Diameter (mm)	406		406		305
4. Length of Screen (m)	9.1		10.9		10.4
5. Depth to top of Screen (m)	29		25		24.4
6. Safe Yield (L/s)	47.3	28.4	20.8	21	20.5

In emergency conditions, the Village of Montrose's water supply is supplemented by the neighbouring Beaver Falls Water Works District system.

### 2.3 Treatment

2013 saw completion of a \$1.5M supply and treatment project funded almost entirely through the federal Gas Tax Strategic Initiatives program. This project included construction of a chlorine room, a baffled 90m<sup>3</sup> chlorine contact chamber, electrical and controls room and a mechanical/pump room.

Chlorine is injected at the Water Treatment Plant at a rate of 0.75 – 1.0 mg/l with the majority of the distribution system seeing concentrations of 0.5 – 0.7mg/l. The injection rates fluctuate during the year with the minimum requirement of 0.2 mg/l residual at distribution system extremities used as a control. There are many challenges in maintaining these limits and dead-end main lines, dual pressure zones, water use and temperatures all affect the required chlorine residual.



The PW department monitors and records residual levels at various locations within the Village generally three times per week. These levels assist the crew in determining the adjustments to the injection rate to maintain the limits in the water distribution system.


A summary of the chlorine concentration monitoring program is found in Appendix 3.

## 2.4 Storage

The Village of Montrose has two reservoirs that store water pumped from the water source.

Reservoir #1 (lower) was constructed in 1959. It is an elevated steel-finished tank consisting of one cell and has a storage capacity of 455m<sup>3</sup>. Its full water level elevation is approximately 637 metres.

Reservoir #2 (upper) was constructed in 1979. It is also an elevated steel-finished tank consisting of one cell and has a storage capacity of 909m<sup>3</sup>. Its full water level elevation is approximately 689 metres.



## 2.5 Distribution System

The Village's distribution system is segregated into 2 different pressure zones. Reservoir #2 services the highest pressure zone, which encompasses the northeast portion of the Village, namely most of 12<sup>th</sup> Avenue, upper 7<sup>th</sup> Street and the Golden Acres subdivision properties. Reservoir #1 services the lower pressure zone, which encompasses the rest of the Village.

In total, the Village of Montrose has approximately thirteen (13) kilometers of water main within the Villages boundaries, comprised of mainly asbestos concrete (approximately 90%), ductile iron (5%), and polyvinyl chloride or PVC (5%) pipes. Sizes range from 50 mm to 250 mm in diameter. As well, the Village's has numerous standpipes, and forty-one (41) fire hydrants for fire protection.

The Village of Montrose distribution system also currently has two connection points with the Beaver Falls Waterworks District distribution system. This allows either system to be used as a backup water supply by the other in emergency and other situations. IHA approved interconnects were installed in 2012 at both the 12<sup>th</sup> and 10<sup>th</sup> Avenue connections.

A new sharing procedure will need to be developed due to the recent addition of treatment to the Montrose system.

## 2.6 Controls and Communications

Programmable Logic Controllers, (PLC's) are digital computers used for automation of the Villages' water system controls. The PLC units control the operation of the wells through connected telephone lines, the Village's SCADA software is able to monitor sensors at source, pumping and storage points within the distribution system to maintain adequate supply and fireflow levels. Interpreting the data received, the software is able to automatically turn pumps on and off, and keep the system running smoothly. When any sign of trouble is detected, the software issues alarms to notify the Village's staff.

### **3.0 Water System Maintenance**

---

In 2014, the Village of Montrose employed three utility maintenance workers that oversaw the operation and maintenance of the Village's water system. The Village has numerous maintenance policies in place related to the day-to-day operation and maintenance of the domestic water system. This includes items such as daily routine inspections of all water distribution system components and general maintenance procedures related to specific problems identified during those inspections. In addition, the Village also performs additional maintenance programs to ensure the integrity of the domestic water supply system. The following provides a general overview of these programs.

#### **3.1 Wells Maintenance**

Except for major items related to well maintenance (i.e. new screen or casing installations), the Village is able to keep well maintenance activities in-house. Village staff performs routine preventative maintenance service programs related to well maintenance, including pump maintenance, general pump house inspections and record keeping.

#### **3.2 Reservoir Maintenance**

Canadian Dewatering out of Edmonton, AB performed inspection and cleaning duties of both Village potable water reservoirs in 2010. Well levels and service was maintained during the works which was completed by divers.

During this cleaning it was noted that the reservoirs did not accumulate debris and recommended cleaning be completed on a ten-year schedule. Canadian Dewatering typically provides the following services when completing maintenance and inspection measures relating to the Village reservoirs:

- Sediment Removal from reservoirs floor using vacuum technique;
- Visual NDT underwater inspection of reservoirs including inspection of wall conditions, outside roof panel, centre support column, overflow pipe, inlet/outlet, bottom/floor, vent, and access hatch/ladder;
- Underwater cleaning using pneumatic tools;
- Recording of CCTV inspection with underwater video system; and
- Summarizing inspection findings.

#### **3.3 Distribution System Maintenance**

The distribution system in the Village of Montrose consists of watermains, valves, service connections, fire hydrants and dedicated sampling locations. Proper maintenance of the distribution system allows the Village to monitor both the quality and quantity of water as well as to take a proactive approach to mitigate potential causes for concern.


##### *3.3.1 Valve Inspection*

The Village tries to inspect all valves located within the distribution system each year to expose any buried valves, make repairs, and to exercise all valves to determine proper

functioning (opening and closing) of valves in order to ensure that specific watermains can be isolated for repair or to ensure that no restrictions are present that may limit flows.

### *3.3.2 Watermain Flushing and Hydrant Maintenance*

In 2011, TRUE Consulting was engaged to provide the Village with a formal unidirectional flushing (UDF) program for the annual flushing of watermains. The 2013 annual flushing program was completed in the spring. The Village also maintains hydrants within the Village where the mains are also exposed to flushing activities.



Hydrants are inspected yearly to determine the unit's ability to function properly, and to provide adequate fire protection. Village staff performs inspections such as checking the hydrant pressure, exposing any worn parts, and updating service records. In 2009, the Village began a program to replace all old fire hydrants.

### *3.3.3 Watermain Breaks*

Unfortunately, municipalities will always have to deal with both unexpected watermain breaks and the disruption of those breaks to the domestic water system. However, most problems associated with breaks can be remedied in a short amount of time and thus, regular service can be quickly restored. The Village experienced a minor watermain break in 2013 which surfaced quickly and was repaired immediately.



#### **4.0 Water System Operator Training Program**

---

The Village's Water Distribution (WD) system is classed as a Level II water system through the Environmental Operators Certificate Program EOCP. This classification level is based on system complexities and the number of homes serviced. The Conditions of Permit to operate the water system are established and monitored by IHA and call for continual operator training and upgrading as well as the attainment of operator certification levels applicable to the level of classification of the municipal water system.

In 2014 the Village had one certified Level II WD full time water system operator and two Utility Operators containing Level I WD. Each of the water operators take new courses each year through the Village's established Training Program in order to upgrade and/or keep current their operator certificates and knowledge to provide the Village with safe and efficient water system operations.

It is planned that the Village will soon see a second Level II WD operator through the efforts of our Training Program. Additionally, the Village is fortunate to live in close proximity and have positive working relationships with other local governments which allows for the sharing of knowledge and information between certified operators.

## 5.0 Water Quality Monitoring and Testing Program

---

The Drinking Water Protection Regulation sets minimal guidelines that water purveyors must meet in respect to water monitoring analysis. Therefore, the Village of Montrose is required to maintain the following components within its testing program:

1. Monitor the drinking water source, the water in its system and the water it provides;
2. Monitor the above not less than 4 times per month;
3. Monitor for both Total Coliform bacteria and E. Coli;
4. Have the analyses required for monitoring carried out by accredited laboratories that meet the requirements of the Drinking Water Protection Act and Public Health Officer; and
5. Send monthly reports to the Public Health Inspector that summarize the above test results and daily water consumption totals.

In 2014, the regular sampling program of the Village provided samples from four locations per testing week as follows:

- 12<sup>th</sup> Avenue Sampling Station;
- Community Hall – 460 9<sup>th</sup> Ave;
- Well #1 – Wells Property, Highway 22A; and
- Well #3 – Wells Property, Highway 22A.

In addition to the sampling above, the Village also completes Comprehensive Drinking Water Analysis. This analysis provides information relating to inorganic parameters and total recoverable metals. This comprehensive water analysis will be done once every three years (minimum) as per the Public Health Inspector, IHA. Well #2 was completed in 2011, Well #1 in 2012, and Well #3 was completed in 2013 upon commissioning of the new treatment facility.

All water analysis on domestic water in the Village of Montrose is performed by CARO Analytical Services, located in Kelowna, BC. CARO Analytical Services employs methods, which are based on those foundations in “Standard Methods for the Examination of Water and Wastewater”, online Edition, published by the American Public Health Association, US EPA protocols found in “Test Methods for Evaluating Solid Waste, Physical/ Chemical Methods, SW846”, 3<sup>rd</sup> Edition and protocols published by the British Columbia Ministry of Environment.



### 5.1 Parameters


A maximum allowable concentration (MAC) has been established by Health Canada for microbiological criteria. Each MAC has been designed to safeguard human health and is based on projecting lifelong consumption of drinking water that contains the substances

at the maximum concentration level. These MAC's are identified in Schedule A of the Drinking Water Protection Regulation as follows:

<b>Water Quality Standards for Potable Water</b>	
<b>Parameter:</b>	<b>Standard:</b>
Fecal coliform bacteria	No detectable fecal coliform bacteria per 100 ml
Escherichia coli	No detectable Escherichia coli per 100 ml
Total coliform bacteria	
(a) 1 sample in a 30 day period	No detectable total coliform bacteria per 100 ml
(b) more than 1 sample in a 30 day period	At least 90% of samples have no detectable total coliform bacteria per 100 ml and no sample has more than 10 total coliform bacteria per 100 ml

## 5.2 Results

The Village's monthly water sampling results are summarized in Appendix 2. Overall results indicate that the Village falls within the required Maximum Allowable Concentrations specified by Health Canada and the Drinking Water Protection Regulations in respect to both Total Coliform and E. coli concentrations.



However, results indicated that the Village received one E. Coli hit in early August and had Background Colonies of less than 200 in one sample in early June. There were no positive E. coli concentrations found in any samples in 2014.

For comparison, in 2013, the Village fell outside of the required Maximum Allowable Concentrations allowed by Health Canada and the Drinking Water Protection Regulations in respect to Total Coliform concentrations in two of the twelve months.

Overall system sampling results indicate that in 2014, the Village routinely fell well within the required Maximum Allowable Concentrations allowed by Health Canada and the Drinking Water Protection Regulations in respect to E. coli concentrations.

**Village of Montrose Water Sampling Results Summary for 2014**

Month or Year(s) [mmm-yy]	Distribution System			Wells			Dist. System and Wells Combined		
	Detectable Samples [#]	Total Samples [#]	Non-detectable Samples [%]	Detectable Samples [#]	Total Samples [#]	Non-detectable Samples [%]	Detectable Samples [#]	Total Samples [#]	Non-detectable Samples [%]
<b>Monthly Totals</b>									
Jan-2014	0	4	100%	0	4	100%	0	8	100%
Feb-2014	0	4	100%	0	4	100%	0	8	100%
Mar-2014	0	4	100%	0	4	100%	0	8	100%
Apr-2014	0	4	100%	0	4	100%	0	8	100%
May-2014	0	4	100%	0	4	100%	0	8	100%
Jun-2014	0	4	100%	1	4	75%	1	8	88%
Jul-2014	0	4	100%	0	4	100%	0	8	100%
Aug-2014	1	4	75%	0	4	100%	1	8	88%
Sep-2014	0	4	100%	0	4	100%	0	8	100%
Oct-2014	0	4	100%	0	4	100%	0	8	100%
Nov-2014	0	4	100%	0	4	100%	0	8	100%
Dec-2014	0	4	100%	0	4	100%	0	8	100%
<b>Annual Totals</b>									
2009	5	97	95%	0	4	100%	5	101	95%
2010	14	106	87%	10	96	90%	24	202	88%
2011	16	102	84%	12	75	84%	28	177	84%
2012	15	72	79%	14	62	77%	29	134	78%
2013	2	64	97%	4	61	93%	6	125	95%
2014	1	48	98%	1	48	98%	2	96	98%
<b>Five-Year Totals</b>									
2010-2014	48	392	88%	41	342	88%	89	734	88%

12<sup>th</sup> Avenue Sampling Station & Community Hall

The 12<sup>th</sup> Avenue Sampling Station and the Community Hall are two primary locations for water sampling of the distribution system within the Village. These samples are generally taken the first and third Tuesday of each month. In 2014, results from the 12<sup>th</sup> Avenue Sampling Station indicated no abnormal counts in respect to E.coli, Total Coliform or Background Colonies. The Community Hall showed one E. coli count of 1 in August but no counts of Total Coliform or Background Colonies.

Well Pump Houses

The Well Pump Houses are also two primary locations for water sampling, and these samples are also generally taken the first and third Tuesday of each month. In 2014, results from the Well Pump Houses ( Well #1 & #3) indicated no abnormal counts in respect to E. coli or Total Coliform; however there was one instance of Background Colonies of less than 200 in June at Well #2.

## 6.0 Annual Consumption Records

Consumption data in 2014 is now expected to be presented with confidence and accuracy, as the construction of the new treatment plant allowed for a new in-line flow meter to be installed in order to monitor accurate annual flow data. In 2014, the Village consumed an average of approximately 520 L/d (population of 1,020).

In 2011, 58% of Canadian households were equipped with water meters compared to 52% in 1991. Over the same period, average daily water use dropped by 27% from 342 litres per person in 1991 to 251 litres per person in 2011 [Environment Canada – Residential Water Use in Canada].

*Table 1 - 2013 / 2014 Water Consumption Comparisons*

Month	2013		2014	
	ML	ML/day average	ML	ML/day average
Jan	7.572	0.244	10,980	0.354
Feb	6.702	0.239	8,186	0.292
Mar	9.104	0.294	9,732	0.314
Apr	0.000	0.000	10,533	0.351
May	0.000	0.000	15,220	0.491
Jun	11.019	0.367	24,320	0.811
Jul	35.500	1.145	32,842	1.059
Aug	31.548	1.018	31,030	1.001
Sep	20.285	0.676	22,105	0.737
Oct	8.884	0.287	12,311	0.397
Nov	4.831	0.161	8,320	0.277
Dec	10.160	0.328	8,174	0.264
yearly total	145.605		193,753	
monthly avg.	12.134	0.397	16,146	0.529

Note: 2013 Data - Treatment facility construction period shown in red, no data available.

The Village of Montrose has been looking to achieve a reduction in the average consumption rate through participation in the Columbia Basin Trust Water Smart program and through enforcement of water usage bylaw #702, implemented in April 2013.

## 7.0 Water Conservation

---

In 2010, the Village of Montrose became a signatory to the Columbia Basin Water Smart Initiative which has assisted local governments across the region to reduce their local water consumption. The two main ways to achieve this reduction is through

1. reducing the amount of water used on lawns and gardens (Outdoor Irrigation); and
2. reducing the amount of water that leaks out of drinking water systems.

A Village of Montrose Water Smart Action Plan was completed in 2010 as part of this initiative which identified that the most significant use of water in Montrose appears to be for domestic irrigation. Leakage within the Village's water system is considered negligible because the estimated rate of indoor domestic use is approximately equivalent to the average winter day demand.

In 2011, 2012, and again in 2013 the Village participated in the CBT Water Ambassador Program through a partnership with the Village of Fruitvale. The ambassadors' goal was to reduce outdoor water use in the summer and her duties included public education, municipal park water use audits and free lawn and garden water assessments, which helped residents understand the amount of water their properties need, and how much water is really required. She also educated residents about watering restrictions.

The program was more successful in 2012 and saw a reduction in assessments in 2013. The Ambassador program is a recommended program in the Water Smart Action Plan. The CBT continues to assess the program and it is expected that further improvements will provide a greater utilization of the program by Montrose residents which will reduce water consumption.

Other Water Smart initiatives included water loss management training, completion of ICI metering in the Village and meter pit installation to the Village's WWTP.

## **8.0 Water Issues in 2014**

---

The Village had no major issues concerning water treatment, supply and/or distribution in 2014; however minor issues continue to present themselves within the water distribution service and are summarized below.

### **Minor Source and Distribution System Interruptions**

General source, pumping and distribution system interruptions occur on an irregular basis due to many factors, including, but not limited to the following:

- Power Supply Outage,
- Power Supply Interruptions or Spikes,
- Controls Communications Loss and/or Failure,
- Water Main Leaks and Repairs, and
- Service Connections Repairs.

## **9.0 2014 Capital Works and Projected 2015 Capital Works**

---

The Village has maintained a philosophy of approaching infrastructure related problems in a proactive manner. This is evident by the numerous studies undertaken in regards to the water distribution piping network and an assortment of issues related to water consumption.

### **2014 Capital Works Projects**

#### **Reservoir Structural Components – Roof Upgrades**

This project aims to reinforce the upper reservoir roof structure through the addition of roof angles to the existing roof support ribs. This project was identified in the 2010 Water Master Plan. The project commenced in 2014 with completion of the lower reservoir inspection to determine if the channel members are actually welded to the roof plate or not. Preliminary budget numbers were received to ensure sufficient funds could be allocated for further design and construction activities in 2015.

#### **Fire Hydrant and Valve Replacement Programs**

This program saw no replacement activities in respect to either gate valves or fire hydrants, as during routine inspections, all current infrastructure was deemed to be functioning well and in good repair.

#### **Water Distribution Pipe Assessment**

Previous pipe assessments completed by the Village required the physical removal of a 2.4m length of pipe to be shipped to a consultant in the Lower Mainland. From that sample, it was determined that the Village look into conducting an acoustic-based technology to assess the condition of all AC pipe within the distribution system. The project commenced in 2014 and a final report is expected to be delivered in early 2015.

#### **Cross Connection Control Plan Implementation**

As per IHA Permit, the Village is required to have a Cross Connection Control Program to identify, eliminate and prevent cross connections with non-potable water sources for the Village of Montrose. Initial contact was made with a consultant to assist the Village in the development of the plan with some of its implementation in 2014 and further implementation in 2015.

### **Projected 2015 Capital Works**

#### **Lower Reservoir Structural Components – Roof Upgrades**

This project is identified above and in 2015, additional engineering assessment and design work is planned to review the suitability of this project. Additionally, it may be cost effective to inspect the upper reservoir during this project in order to determine if a repairs are required at this stage and if so, if they can be deferred to a future year.



Well Site - Valve upgrades

The need for a high pressure valve and blow-off to provide for a flush point for the supply main was determined after design of the wells project. This change did not occur during WTP construction or operational activities in 2014; however, the Village will need to complete this project in 2015.

Fire Hydrant and Valve Replacement Programs


This program will continue in 2015 and will plan to incorporate the replacement of some fire hydrants, exercise of main line valves, extension of a gate valve to road surface on 11th Avenue, and locating / accessing valves currently within Village right-of-ways.

Annual review and completion of the work program improves the water service to residents in the Village and will result in a reduction to disruptions during future waterworks projects.

## 10.0 Emergency Response and Contingency Plan

---

The Village currently has in place policies that deal with water quality notification (Policy # 5600) and emergency call outs (Policy # 7130). Both policies may be found in Appendix 4. The water quality notification Policy #5600 was revised in early 2009 as per the requirements of the Public Health Inspector, IHA.



When a major emergency occurs with respect to water supply, the Village of Montrose and the Beaver Falls Waterworks District have an agreement in place that allows either water system to act as a back-up system for the other. The process of backing up either system includes the fact that qualified representatives from each water system are present and work together to open the necessary valves for the systems to be properly combined. Further, the Village and Beaver Falls representatives convene regularly to discuss any upgrades to each respective distribution system and provide updates on a variety of other water purveyor matters common to both systems.

Formal Response Plans for specific emergency events are being developed and will be completed in 2015.

## 11.0 Conclusion

---

Since the implementation of the *Drinking Water Protection Act* and Drinking Water Protection Regulations, standards with respect to on-going operator training, water sampling, system monitoring, emergency response plans, long-range planning and public reporting have increased dramatically.

The Village of Montrose looks forward to the continuous implementation of this new legislation and welcomes the opportunity to inform residents of the Village's practices relating to the supply and distribution of domestic potable water. Further, as a result of presenting this annual report, the Village hopes that residents understand the current complexities municipalities face in supplying an adequate water source to its residents, and encourages residents to help the Village maintain a safe, reliable water source for both current and future generations.



VILLAGE OF MONTROSE

2014 ANNUAL REPORT OF WATER MONITORING

---

APPENDIX 1

Montrose Water Service Area

General Notes  
 1. THE LOCATION OF ALL EXISTING UTILITIES SHOWN ARE BASED ON FIELD SURVEY AND RECORD DRAWING DATA.

NO.	DATE	BY	DESCRIPTION
1	08-21-10	REVISOR/NAME	DATE
2	08-21-10	REVISOR/NAME	DATE
3	08-21-10	REVISOR/NAME	DATE
4	08-21-10	REVISOR/NAME	DATE
5	08-21-10	REVISOR/NAME	DATE
6	08-21-10	REVISOR/NAME	DATE
7	08-21-10	REVISOR/NAME	DATE
8	08-21-10	REVISOR/NAME	DATE
9	08-21-10	REVISOR/NAME	DATE
10	08-21-10	REVISOR/NAME	DATE



**VILLAGE OF MONTROSE**

545 11TH AVENUE  
 PO BOX 210  
 MONTROSE, CO 81401  
 PHONE: 970.241.2100  
 WWW.VILLAGEOFMONTROSE.COM

PROJECT NO. \_\_\_\_\_  
 SHEET NO. \_\_\_\_\_

**WATER SERVICE AREA  
 VILLAGE OF MONTROSE**

Project No.	Sheet	1 of 1
1:2500	Date	SEPT 22, 2009
Scale	Sheet	A



**LEGEND**

- VALVE
- HYDRANT
- BLOW OFF
- WATER MAIN
- MUNICIPAL BOUNDARY



VILLAGE OF MONTROSE

2014 ANNUAL REPORT OF WATER MONITORING

---

APPENDIX 2

2014 Drinking Water Bacteriology Summary

## APPENDIX 2

### Village of Montrose 2014 Water Quality Testing Records

All testing carried out by CARO Environmental Services of Kelowna (250)765-9646  
Tested for Total Coliforms & E. Coli

#### JANUARY 2014

Date	Location	Total Coliform	E. Coli
07-Jan	12th Ave Sample Station	<1	<1
07-Jan	Community Hall - 490 9th Ave	<1	<1
07-Jan	Well Pump #1 - Hwy 22A	<1	<1
07-Jan	Well Pump #2 - Hwy 22A	<1	<1
21-Jan	12th Ave Sample Station	<1	<1
21-Jan	Community Hall - 490 9th Ave	<1	<1
21-Jan	Well Pump #1 - Hwy 22A	<1	<1
21-Jan	Well Pump #2 - Hwy 22A	<1	<1

#### FEBRUARY 2014

Date	Location	Total Coliform	E. Coli
04-Feb	12th Ave Sample Station	<1	<1
04-Feb	Community Hall - 490 9th Ave	<1	<1
04-Feb	Well Pump #1 - Hwy 22A	<1	<1
04-Feb	Well Pump #2 - Hwy 22A	<1	<1
18-Feb	12th Ave Sample Station	<1	<1
18-Feb	Community Hall - 490 9th Ave	<1	<1
18-Feb	Well Pump #1 - Hwy 22A	<1	<1
18-Feb	Well Pump #2 - Hwy 22A	<1	<1

#### MARCH 2014

Date	Location	Total Coliform	E. Coli
04-Mar	12th Ave Sample Station	<1	<1
04-Mar	Community Hall - 490 9th Ave	<1	<1
18-Mar	12th Ave Sample Station	<1	<1
18-Mar	Community Hall - 490 9th Ave	<1	<1
18-Mar	Well Pump #1 - Hwy 22A	<1	<1
18-Mar	Well Pump #2 - Hwy 22A	<1	<1

**APRIL 2014**

<b>Date</b>	<b>Location</b>	<b>Total Coliform</b>	<b>E. Coli</b>
01-Apr	12th Ave Sample Station	<1	<1
01-Apr	Community Hall - 490 9th Ave	<1	<1
01-Apr	Well Pump #1 - Hwy 22A	<1	<1
01-Apr	Well Pump #2 - Hwy 22A	<1	<1
15-Apr	12th Ave Sample Station	<1	<1
15-Apr	Community Hall - 490 9th Ave	<1	<1
15-Apr	Well Pump #1 - Hwy 22A	<1	<1
15-Apr	Well Pump #2 - Hwy 22A	<1	<1

**MAY 2014**

<b>Date</b>	<b>Location</b>	<b>Total Coliform</b>	<b>E. Coli</b>
06-May	12th Ave Sample Station	<1	<1
06-May	Community Hall - 490 9th Ave	<1	<1
06-May	Well Pump #1 - Hwy 22A	<1	<1
06-May	Well Pump #3 - Hwy 22A	<1	<1
21-May	12th Ave Sample Station	<1	<1
21-May	Community Hall - 490 9th Ave	<1	<1
21-May	Well Pump #1 - Hwy 22A	<1	<1
21-May	Well Pump #3 - Hwy 22A	<1	<1

**JUNE 2014**

<b>Date</b>	<b>Location</b>	<b>Total Coliform</b>	<b>E. Coli</b>	<b>Background Colonies</b>
03-Jun	12th Ave Sample Station	<1	<1	
03-Jun	Community Hall - 490 9th Ave	<1	<1	
03-Jun	Well Pump #1 - Hwy 22A	<1	<1	
03-Jun	Well Pump #2 - Hwy 22A	<1	<1	>200
17-Jun	12th Ave Sample Station	<1	<1	
17-Jun	Community Hall - 490 9th Ave	<1	<1	
17-Jun	Well Pump #1 - Hwy 22A	<1	<1	
17-Jun	Well Pump #2 - Hwy 22A	<1	<1	



**JULY 2014**

<b>Date</b>	<b>Location</b>	<b>Total Coliform</b>	<b>E. Coli</b>
08-Jul	12th Ave Sample Station	<1	<1
	Community Hall - 490 9th Ave		
08-Jul	Well Pump #1 - Hwy 22A	<1	<1
08-Jul	Well Pump #3 - Hwy 22A	<1	<1
22-Jul	12th Ave Sample Station	<1	<1
22-Jul	Community Hall - 490 9th Ave	<1	<1
22-Jul	Well Pump #1 - Hwy 22A	<1	<1
22-Jul	Well Pump #3 - Hwy 22A	<1	<1

**AUGUST 2014**

<b>Date</b>	<b>Location</b>	<b>Total Coliform</b>	<b>E. Coli</b>
06-Aug	BS4 12th Ave Sample Station	<1	<1
06-Aug	BS3 Community Hall - 490 9th Ave	<1	<b>1</b>
06-Aug	BS1 Well Pump #1 - Hwy 22A	<1	<1
06-Aug	BS2 Well Pump #2 - Hwy 22A	<1	<1
19-Aug	BS4 12th Ave Sample Station	<1	<1
19-Aug	BS3 Community Hall - 490 9th Ave	<1	<1
19-Aug	BS1 Well Pump #1 - Hwy 22A	<1	<1
19-Aug	BS2 Well Pump #2 - Hwy 22A	<1	<1

**SEPTEMBER 2014**

<b>Date</b>	<b>Location</b>	<b>Total Coliform</b>	<b>E. Coli</b>
03-Sept	12th Ave Sample Station	<1	<1
03-Sept	Community Hall - 490 9th Ave	<1	<1
03-Sept	Well Pump #1 - Hwy 22A	<1	<1
03-Sept	Well Pump #2 - Hwy 22A	<1	<1
16-Sept	12th Ave Sample Station	<1	<1
16-Sept	Community Hall - 490 9th Ave	<1	<1
16-Sept	Well Pump #1 - Hwy 22A	<1	<1
16-Sept	Well Pump #2 - Hwy 22A	<1	<1

**OCTOBER 2014**

<b>Date</b>	<b>Location</b>	<b>Total Coliform</b>	<b>E. Coli</b>
07-Oct	12th Ave Sample Station	<1	<1
07-Oct	Community Hall - 490 9th Ave	<1	<1
07-Oct	Well Pump #1 - Hwy 22A	<1	<1
07-Oct	Well Pump #2 - Hwy 22A	<1	<1
21-Oct	12th Ave Sample Station	<1	<1
21-Oct	Community Hall - 490 9th Ave	<1	<1
21-Oct	Well Pump #1 - Hwy 22A	<1	<1
21-Oct	Well Pump#2 - Hwy 22A	<1	<1

**NOVEMBER 2014**

<b>Date</b>	<b>Location</b>	<b>Total Coliform</b>	<b>E. Coli</b>
04-Nov	12th Ave Sample Station	<1	<1
04-Nov	Community Hall - 490 9th Ave	<1	<1
04-Nov	Well Pump #1 - Hwy 22A	<1	<1
04-Nov	Well Pump #2 - Hwy 22A	<1	<1
18-Nov	12th Ave Sample Station	<1	<1
18-Nov	Community Hall - 490 9th Ave	<1	<1
18-Nov	Well Pump #1 - Hwy 22A	<1	<1
18-Nov	Well Pump#2 - Hwy 22A	<1	<1

**DECEMBER 2014**

<b>Date</b>	<b>Location</b>	<b>Total Coliform</b>	<b>E. Coli</b>
02-Dec	12th Ave Sample Station	<1	<1
02-Dec	Community Hall - 490 9th Ave	<1	<1
02-Dec	Well Pump #1 - Hwy 22A	<1	<1
02-Dec	Well Pump #2 - Hwy 22A	<1	<1
16-Dec	12th Ave Sample Station	<1	<1
16-Dec	Community Hall - 490 9th Ave	<1	<1
16-Dec	Well Pump #1 - Hwy 22A	<1	<1
16-Dec	Well Pump#2 - Hwy 22A	<1	<1



VILLAGE OF MONTROSE

2014 ANNUAL REPORT OF WATER MONITORING

---

APPENDIX 3

2014 Chlorine Residual Monitoring Summary

## APPENDIX 3

### Village of Montrose 2014 Chlorine Residual Monitoring Summary

	January		February		March		April	
	WTP	Dist.	WTP	Dist.	WTP	Dist.	WTP	Dist.
Total Samples	13	38	129	37	12	46	12	37
Month High (ppm)	0.80	0.83	0.83	0.80	0.80	0.80	0.77	0.87
Month Low (ppm)	0.71	0.37	0.67	0.35	0.62	0.30	0.57	0.25
Month Average (ppm)	0.76	0.62	0.75	0.64	0.71	0.64	0.69	0.59

	May		June		July		August	
	WTP	Dist.	WTP	Dist.	WTP	Dist.	WTP	Dist.
Total Samples	11	41	13	41	13	43	12	45
Month High (ppm)	0.82	0.82	0.82	1.10	0.76	0.84	0.88	1.00
Month Low (ppm)	0.68	0.30	0.56	0.21	0.51	0.25	0.60	0.25
Month Average (ppm)	0.73	0.64	0.69	0.59	0.68	0.61	0.70	0.63

	Sept		Oct		November		December	
	WTP	Dist.	WTP	Dist.	WTP	Dist.	WTP	Dist.
Total Samples	12	44	13	52	12	45	13	52
Month High (ppm)	0.77	0.77	0.78	0.78	0.75	0.77	0.74	0.72
Month Low (ppm)	0.60	0.29	0.63	0.33	0.62	0.34	0.63	0.36
Month Average (ppm)	0.70	0.63	0.71	0.64	0.69	0.62	0.68	0.60

WTP = Water Treatment Plant - Analyzer Data

Dist. = Distribution System - samples taken from various locations within Village

All measurements represent free Cl<sub>2</sub> (mg/L)



VILLAGE OF MONTROSE

2014 ANNUAL REPORT OF WATER MONITORING

---

APPENDIX 4

2014 Water Consumption Records

## APPENDIX 4

### Village of Montrose 2014 Water Consumption Records

JANUARY 2014 TOTALS			FEBRUARY 2014 TOTALS		
Day		Total Daily	Day		Total Daily
January	1	329,697	February	1	253899
January	2	398,924	February	2	343962
January	3	349,439	February	3	265236
January	4	325,309	February	4	310911
January	5	404,072	February	5	no data
January	6	378,116	February	6	332291
January	7	327,700	February	7	282622
January	8	379,211	February	8	341853
January	9	350,099	February	9	292987
January	10	332,759	February	10	337952
January	11	328,834	February	11	255933
January	12	443,101	February	12	315658
January	13	382,054	February	13	258626
January	14	393,068	February	14	307845
January	15	310,598	February	15	259537
January	16	397,794	February	16	342123
January	17	309,231	February	17	328485
January	18	391,446	February	18	275708
January	19	341,041	February	19	344804
January	20	402,286	February	20	285481
January	21	325,962	February	21	331687
January	22	410,312	February	22	291617
January	23	336,131	February	23	328026
January	24	357,527	February	24	286523
January	25	337,279	February	25	336001
January	26	396,698	February	26	274507
January	27	383,686	February	27	336071
January	28	283,908	February	28	265616
January	29	311,376			
January	30	250,406			
January	31	312,264			
<b>January Total</b>		<b>10,980,328</b> Litres	<b>February Total</b>		<b>8,185,961</b> Litres

**MARCH 2014 TOTALS**

Day	Total Daily
March 1	319,132
March 2	292,313
March 3	347,749
March 4	341,934
March 5	268,516
March 6	341,649
March 7	273,750
March 8	356,879
March 9	292,988
March 10	342,595
March 11	292,547
March 12	336,269
March 13	281,882
March 14	331,406
March 15	335,447
March 16	294,853
March 17	349,997
March 18	279,390
March 19	336,094
March 20	280,906
March 21	336,446
March 22	263,866
March 23	336,332
March 24	296,172
March 25	286,061
March 26	349,308
March 27	285,848
March 28	344,061
March 29	294,902
March 30	349,234
March 31	293,932
<b>March Total</b>	<b>9,103,981 Litres</b>

**APRIL 2014 TOTALS**

Day	Total Daily
April 1	349,762
April 2	292,186
April 3	293,372
April 4	344,923
April 5	298,812
April 6	370,718
April 7	446,519
April 8	321,241
April 9	280,713
April 10	325,007
April 11	268,138
April 12	304,879
April 13	414,439
April 14	398,915
April 15	377,505
April 16	284,071
April 17	347,060
April 18	370,277
April 19	342,655
April 20	445,157
April 21	367,941
April 22	282,786
April 23	360,659
April 24	340,154
April 25	404,570
April 26	336,557
April 27	420,893
April 28	367,657
April 29	436,829
April 30	338,204
<b>April Total</b>	<b>9,103,981 Litres</b>

**MAY 2014 TOTALS**

Day	Total Daily
May 1	439,407
May 2	420,189
May 3	442,674
May 4	463,256
May 5	412,803
May 6	307,321
May 7	352,968
May 8	350,808
May 9	403,994
May 10	435,375
May 11	519,386
May 12	489,863
May 13	507,212
May 14	471,529
May 15	513,237
May 16	554,001
May 17	563,764
May 18	439,598
May 19	502,208
May 20	499,082
May 21	520,783
May 22	546,387
May 23	537,736
May 24	589,304
May 25	633,063
May 26	509,353
May 27	547,061
May 28	469,602
May 29	463,868
May 30	458,148
May 31	658,019

**May Total 15,021,999 Litres**

**JUNE 2014 TOTALS**

Day	Total Daily
June 1	878,782
June 2	722,402
June 3	819,863
June 4	890,910
June 5	800,628
June 6	958,988
June 7	1,100,000
June 8	1,100,000
June 9	1,100,000
June 10	1,010,000
June 11	1,100,000
June 12	881,045
June 13	686,652
June 14	665,599
June 15	724,450
June 16	628,702
June 17	551,646
June 18	548,325
June 19	591,430
June 20	611,928
June 21	861,525
June 22	1,040,000
June 23	1,020,000
June 24	895,124
June 25	825,253
June 26	795,594
June 27	761,143
June 28	562,282
June 29	616,011
June 30	571,607

**June Total 24,319,889 Litres**



**JULY 2014 TOTALS**

Day	Total Daily
July 1	862,449
July 2	704,916
July 3	950,842
July 4	976,318
July 5	1,330,000
July 6	1,060,000
July 7	910,156
July 8	991,391
July 9	1,150,000
July 10	1,000,000
July 11	1,150,000
July 12	1,380,000
July 13	1,380,000
July 14	744,342
July 15	1,100,000
July 16	1,120,000
July 17	1,170,000
July 18	1,090,000
July 19	1,440,000
July 20	1,190,000
July 21	1,010,000
July 22	991,461
July 23	1,010,000
July 24	620,563
July 25	790,997
July 26	1,140,000
July 27	1,250,000
July 28	1,050,000
July 29	1,280,000
July 30	1,090,000
July 31	908,438
<b>July Total</b>	<b>32,841,873 Litres</b>

**AUGUST 2014 TOTALS**

Day	Total Daily
August 1	1,230,000
August 2	1,320,000
August 3	1,280,000
August 4	957,034
August 5	1,360,000
August 6	1,160,000
August 7	1,240,000
August 8	1,110,000
August 9	1,590,000
August 10	1,200,000
August 11	1,370,000
August 12	888,437
August 13	1,030,000
August 14	984,757
August 15	773,395
August 16	821,207
August 17	1,000,000
August 18	1,030,000
August 19	824,617
August 20	684,893
August 21	669,361
August 22	637,860
August 23	1,070,000
August 24	785,694
August 25	1,030,000
August 26	602,509
August 27	1,040,000
August 28	717,390
August 29	971,570
August 30	970,071
August 31	680,926
<b>August Total</b>	<b>31,029,721 Litres</b>

**SEPTEMBER 2014 TOTALS**

Day	Total Daily
September 1	896,693
September 2	775,472
September 3	652,023
September 4	587,465
September 5	716,605
September 6	775,350
September 7	925,508
September 8	802,311
September 9	964,379
September 10	723,055
September 11	833,466
September 12	691,437
September 13	864,811
September 14	775,454
September 15	964,924
September 16	694,660
September 17	851,955
September 18	647,963
September 19	725,708
September 20	746,045
September 21	909,923
September 22	731,295
September 23	797,900
September 24	518,005
September 25	582,161
September 26	492,793
September 27	622,640
September 28	619,485
September 29	671,913
September 30	543,195
<b>September Total</b>	<b>22,104,594 Litres</b>

**OCTOBER 2014 TOTALS**

Day	Total Daily
October 1	586,217
October 2	526,418
October 3	507,067
October 4	489,709
October 5	595,038
October 6	576,577
October 7	523,662
October 8	428,482
October 9	489,183
October 10	421,098
October 11	439,526
October 12	414,048
October 13	453,854
October 14	348,997
October 15	406,314
October 16	282,842
October 17	269,719
October 18	295,560
October 19	385,057
October 20	319,591
October 21	374,291
October 22	293,646
October 23	352,524
October 24	268,380
October 25	293,393
October 26	350,252
October 27	327,728
October 28	301,473
October 29	368,962
October 30	301,286
October 31	319,828
<b>October Total</b>	<b>12,310,722 Litres</b>

**NOVEMBER 2014 TOTALS**

Day	Total Daily
November 1	312,176
November 2	360,993
November 3	54,366
November 4	537,141
November 5	283,793
November 6	263,134
November 7	305,540
November 8	274,007
November 9	293,579
November 10	285,968
November 11	294,666
November 12	306,627
November 13	328,373
November 14	295,754
November 15	283,793
November 16	317,500
November 17	328,373
November 18	240,300
November 19	328,373
November 20	306,627
November 21	305,540
November 22	252,260
November 23	252,260
November 24	207,680
November 25	218,553
November 26	185,933
November 27	229,426
November 28	185,933
November 29	229,426
November 30	252,260
<b>November Total</b>	<b>8,320,354 Litres</b>

**DECEMBER 2014 TOTALS**

Day	Total Daily
December 1	250,728
December 2	216,759
December 3	285,751
December 4	214,025
December 5	301,691
December 6	286,078
December 7	282,399
December 8	227,898
December 9	292,962
December 10	250,728
December 11	216,759
December 12	285,751
December 13	214,025
December 14	301,691
December 15	286,078
December 16	224,364
December 17	282,399
December 18	227,898
December 19	292,962
December 20	291,054
December 21	255,852
December 22	291,291
December 23	246,432
December 24	301,470
December 25	215,237
December 26	263,303
December 27	240,446
December 28	227,235
December 29	329,194
December 30	282,547
December 31	289,246
<b>December Total</b>	<b>8,174,253 Litres</b>



VILLAGE OF MONTROSE

2014 ANNUAL REPORT OF WATER MONITORING

---

APPENDIX 5

Emergency Response Plan  
(Policies # 5600 and #7130)

# THE VILLAGE OF MONTROSE

**POLICY TITLE:** WATER QUALITY NOTIFICATION POLICY

**POLICY #** 5600

**POLICY STATEMENT:**

It is the policy of Council to notify users served by the Montrose domestic water system of any water quality problems as soon as the Village becomes aware of a problem or potential problem.

**POLICY BACKGROUND:**

The Village of Montrose has traditionally relied on the provincial Public Health Officer to notify water users of any health problems related to the Montrose water system. With the adoption of the *Drinking Water Protection Act* the Village of Montrose has been assigned the responsibility to test the water and to notify water users of any water related health risks.

**POLICY GOAL:**

It is the goal of this policy to maintain a procedure of efficient and effective notification of users of the Montrose water system in the event of a proven or suspected public health risk associated with the Montrose water supply and distribution system.

**POLICY OBJECTIVES:**

1. For the purpose of maintaining public awareness of the water safety notification protocol, to distribute a copy of this policy, including schedules, annually to each household and business served by the Montrose water system.
2. To issue a "**Water Quality Advisory**" (schedule 'A') when any on of the following conditions apply:
  - a) A leak in a municipal water main line is suspected, but not yet located.  
**Protocol:** posting the notice on the Village and Post Office bulletin boards, and publishing a copy of the notice in the Trail Daily Times newspaper.
  - b) A leak in a municipal water main line is located.  
**Protocol:** posting the notice on the Village and Post Office bulletin board, and distributing a copy of the notice to residences and businesses served by that water main line.
  - c) *Two or more consecutive samples are reported with, or exceeding a total coliform of 10 per 100ml or reported as overgrowth.*  
**Protocol:** *Posting the notice on the Village Post Office bulletin board, publishing a copy of the notice to the Trail Daily Times newspaper, and delivering a notice to local hotels, motels, restaurants, and service stations.*
3. To issue a "**Boil Water Notice**" (schedule 'B') when any on of the following conditions apply:
  - a) An act of nature, e.g., a flood, in the immediate vicinity of one or more of the Village's wells.  
**Protocol:** posting the notice on the Village and Post Office bulletin board.
  - b) One water sample is received indicating presence of E. Coli.  
**Protocol:** posting the notice on the Village and Post Office bulletin board, publishing a copy of the notice in the Trail Daily Times newspaper, and announcing the notice on a weekly basis on CBC Radio and KBS Radio while the condition prevails.

4. To issue a "**Do Not Use Water Notice**" (schedule 'C') when any one of the following conditions apply:
  - a) A spill of a hazardous substance, e.g., liquid fuel, chemicals, etc., or possible contamination of an unknown substance due to vandalism in the immediate vicinity of one or more of the Village's wells.
 

**Protocol:** notification of Regional Emergency Coordinator, posting the notice on the Village and Post Office bulletin board, publishing a copy of the notice in the Trail Daily Times newspaper, and announcing the notice on a daily basis on CBC Radio and KBS Radio while the condition prevails.
  - b) Evidence of both unauthorized entry and suspected interference with a critical component of the water system infrastructure, e.g., a well or water storage tank.
 

**Protocol:** notification of the RCMP and the Regional Emergency Coordinator, posting the notice on the Village and Post Office bulletin board, publishing a copy of the notice in the Trail Daily Times newspaper, and announcing the notice on a daily basis on CBC Radio and KBS Radio while the condition prevails.
5. Notwithstanding the notification protocols for Water Quality, Boil Water, and Do Not Use Water Notices, copies of all notices issued pursuant to this policy shall be forwarded to the Public Health Officer, the Medical Health Officer, the Chair and all Board Members of the Beaver Falls Waterworks District, and the Mayor and all Councillors.
6. At any time, and under any condition, if a notice or a notification protocol other than the one prescribed in this policy is recommended or directed by the Public Health Officer or the Medical Health Officer, such recommendation or direction shall take precedence over this policy.
7. When a condition requiring a Notice pursuant to this policy no longer applies, a request to publish a "**Water Condition Normal Notice**" (schedule 'D') shall be submitted to the Public Health Officer.
8. When approved by the Public Health Officer, a "**Water Condition Normal Notice**" shall be issued following the protocol applicable to the Notice to be withdrawn.
9. The Public Works Foreman shall be responsible for the administration of this policy.

Submitted to the Public Health Officer for review on May 30, 2005.

Initially approved at meeting #15-05 on June 20, 2005.

Revised as per IHA, December 16, 2008

Last reviewed and revised at meeting #01-11 on January 17, 2011.

Last reviewed and confirmed unchanged at meeting #6-14, February 3, 2014

Next scheduled to be reviewed on January 19, 2015

## VILLAGE OF MONTROSE – WATER QUALITY NOTIFICATION POLICY – SCHEDULE 'A'

# **NOTICE**

## **WATER QUALITY ADVISORY**

The Village of Montrose issued this Water Quality Advisory Notice on (date) pursuant to Water Quality Notification Policy #5600.

This Notice has been issued for the following reason(s):  
(description of the problem encountered)

The Public Health Officer has been notified, and measures are being taken to correct the problem.

The risk associated with the problem is considered to be low. Persons with compromised immune systems should boil their drinking water or use bottled water as a precautionary measure.

Further notices will be issued if the condition should deteriorate, or if the risk to public health should increase.

A "Water Condition Normal Notice" will be issued when the Drinking Water Official is satisfied that the risk to public health has been eliminated.

For more information, please contact the Village Office at (250) 367-7234 or the Drinking Water Protection Officer at 1-888-426-7566.

## VILLAGE OF MONTROSE – WATER QUALITY NOTIFICATION POLICY – SCHEDULE 'B'

**BOIL WATER NOTICE**

The Village of Montrose issued this Boil Water Notice on (date) pursuant to Water Quality Notification Policy #5600.

This Notice has been issued for the following reason(s):  
(description of the problem encountered)

The Public Health Officer and the Village's engineers are assessing the problem.

**All users of the Montrose water supply system are warned to:**

- a) Boil the water at a rapid boil for at least two minutes, before using the water.**

Further notices will be issued if the condition should deteriorate, or if the risk to public health should increase.

A "Water Condition Normal Notice" will be issued when the Public Health Officer is satisfied that the risk to public health has been eliminated.

For more information, please contact the Village Office at (250) 367-7234 or the Drinking Water Protection Officer at 1-888-426-7566.



VILLAGE OF MONTROSE – WATER QUALITY NOTIFICATION POLICY – SCHEDULE 'C'

# **DO NOT USE WATER NOTICE**

The Village of Montrose issued this Do Not Use Water Notice on (date) pursuant to Water Quality Notification Policy #5600.

This Notice has been issued for the following reason(s):  
(description of the problem encountered)

The Public Health Officer and the Village's engineers are assessing the problem.

**It is advised that water from the Montrose water system**

## **NOT BE CONSUMED**

**or used in food preparation, performing dental hygiene, showering, bathing, cooking, laundry, or any other purpose that may bring the water in contact with people or animals as the water may be chemically or bacteriologically unsafe.**

Further notices will be issued if the condition should deteriorate, or if the risk to public health should increase.

A "Water Condition Normal Notice" will be issued when the Public Health Officer is satisfied that the risk to public health has been eliminated.

For more information, please contact the Village Office at (250) 367-7234 or the Drinking Water Protection Officer at 1-888-426-7566.

VILLAGE OF MONTROSE – WATER QUALITY NOTIFICATION POLICY – SCHEDULE 'D'

# **NOTICE**

## **WATER CONDITION NORMAL**

The (specify) Notice issued by the Village on (date) pursuant to Water Quality Notification Policy #5600 is hereby rescinded.

The problem has been resolved and the Public Health Officer has confirmed that the quality of the Montrose water system once again meets all public health requirements.

In the event of a reoccurrence of the problem, or a new water quality problem, a new notice will be issued.

For more information, please contact the Village Office at (250) 367-7234 or the Drinking Water Protection Officer at 1-888-426-7566.

# THE VILLAGE OF MONTROSE

**POLICY TITLE:** EMERGENCY CALL-OUT POLICY

**POLICY #** 7130

**POLICY STATEMENT:**

It is the policy of Council to provide an emergency call-out procedure for basic water and sewer service emergencies.

**POLICY BACKGROUND:**

The Village does not have the staffing necessary to provide a standard call-out service to the community. Citizens have been encouraged to call private contractors (e.g. plumbers) to assist in emergencies such as plugged sewers. It is recognized, however, that certain emergency (e.g. broken water mains, failing lift stations) require attendance by the municipality's public works staff.

**POLICY GOAL:**

It is the goal of this policy to provide a basic call-out service to respond to lift station failures and broken water mains outside of regular working hours.

**POLICY OBJECTIVES:**

1. To secure the assistance of the Regional Fire Service to provide an emergency call-out dispatch service.
2. To limit the emergency call-out service to sewer lift-station failures and broken water mains.
3. To establish a phone fan-out sequence:
  - a) **Public Works Foreman (Kevin Ihas) PW Cell # @ 250-231-1554**
  - b) **Public Works Foreman (Kevin Ihas) Personal Cell # @ 250-231-5788**
  - c) **Utility Operator (Chris Morissette) – PW Cell # @ 250-231-1458**
  - d) **Utility Operator (Chris Morissette) – Personal Cell # @ 250-521-1369**
  - e) **Utility Operator (Garnet Bignell) – PW Cell # @ 250-231-4191**
  - f) **Utility Operator(Garnet Bignell) – Personal Cell # @ 250-368-7443**
  - g) **CAO (Kevin Chartres) – Home# @ 250-368-5833 / Cell# @ 250-231-4157**
  - h) **Mayor (Joe Danchuk) – Home# @ 250-367-2120**
4. To advertise the number **250-364-1737** as the *Village of Montrose after-hours and weekend Sewer Lift Station & Water Main Break Emergency Phone.*
5. That the Village of Montrose assume responsibility for any liability that may arise out of the implementation of this policy.

Initially approved at meeting #35-98 on November 17, 1998

Last reviewed and amended at meeting #36-13, November 18, 2013

Last reviewed and confirmed unchanged at meeting #40 – 14, December 1, 2014

Next review scheduled for December 7, 2015